



Certificate of Compliance

Certificate: 1495802

Master Contract: 214197

Project: 1495802

Date Issued: 2004/02/27

Issued to: **Heat Trace Ltd.**
Cromwell Road
SK6 2RF Bredbury
Stockport
UNITED KINGDOM
Attention: Mr. Bo-Hwan Lee

The products listed below are eligible to bear the CSA Mark shown



A handwritten signature in black ink.

Issued by: D. Hawkes

Authorized by: A handwritten signature in blue ink.
Nick Alfano
Operations Manager

PRODUCTS

CLASS 2872 01 - HEATERS - Cable and Cable Sets

Series Heating Cable Sets, cat. no. HTP3F, with TPE insulation, tinned copper braid, and TPE outer jacket, designations 4A and 4B, rated 7W/ft maximum (23W/m maximum), maximum voltage rating 600V (3 phase), maximum current rating 30 Amps, max temperature rating 90°C.

Notes:

1. Installation in accordance with the Canadian Electrical Code, Part I.
2. Heating Cable Sets for Pipe Interior Heating Systems - Installation in metal or non-metallic pipes, tanks, etc.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No 130.2-93 - Heat Cable Systems for Use in Other Than Industrial Establishments



Supplement to Certificate of Compliance

Certificate: 1495802

Master Contract: 214197

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
1495802	2004/02/27	Original Certification.