



TYPE APPROVAL CERTIFICATE

Certificate No:
TAE00002KA
Revision No:
1

This is to certify:

That the Electric Heating Cable

with type designation(s)
**FREEZSTOP EXTRA FSE,
FREEZSTOP EXTRA WIDE FSEw**

Issued to

**Heat Trace Ltd.
Frodsham, CHESHIRE, United Kingdom**

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

Heat trace. Self regulating power output depending on temperature.

Suitable for gas dangerous areas ref. IEC Ex marking on cable.

Products approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Type	Rated voltage (V)	Temp. class (°C)	Power [W/m] @ref. temp.	Suitable for Hazardous areas
FREEZSTOP EXTRA FSE	0-277	135(T4 upto 45W/m)	17/31 @ 10 C	Yes
FREEZSTOP EXTRA WIDE FSEw	0-277	200 (T3 above 45W/m)	45/60 @ 10 C	Yes

Issued at **Høvik** on **2023-03-24**

for **DNV**

This Certificate is valid until **2028-02-05**.

DNV local unit: **UK & Ireland CMC & VMC**

Approval Engineer: **Ivar Bull**

.....
Frederik Tore Elter
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

FREEZSTOP EXTRA FSE,
 FREEZSTOP EXTRA WIDE FSEw

Conductors: 2 parallel bus wires: Stranded metallic conductor
 Heating Conductor Element: Semi-conductive self-limiting matrix
 Insulation: TPE
 Braid: Aluminum sheath or metallic braid
 Sheath: An optional additional outer jacket of TPE/PE/PVDF/MFA/PFA

Type designation	Supply voltage (V)	Nominal Output at 10 °C (w/m)	Type Self regulating / Constant power / Series
17 FSE	110-277	17	Self regulating
31 FSE	110-277	31	Self regulating
45 FSEw	110-277	45	Self regulating
60 FSEw	110-277	60	Self regulating

Maximum continuous exposure temperature (Power ON or OFF) is 100 °C

Application/Limitation

References to Ex-certifications in this type approval is for information only.
 Installation has to be done in accordance with installation instruction.
 The minimum installation temperature of the heating cables is -40°C

Type Approval documentation

- Datasheet: [FSE and FSE\(w\): SRDS0103](#)
- Test reports: [Freezstop Extra \(FSE\) Self Regulating Heating Cables IECEx CML19.0122 2022-06-28](#)
[Freezstop Extra \(FSEw\) Self Regulating Heating Cables IECEx CML 19.0123 2022-06-28](#)
[IECEx Quality Assessment Report: GB/CML/QAR19.0027/05 issued 2022-06-30. Valid until: 2024-08-21](#)

Tests carried out

Tested in accordance with IEC 60079-30-1 Electrical resistance trace heating - General and testing requirements.

Marking of product

HEAT TRACE -Type designation – Gas Marking - Power output at nominal voltage – serial number

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine tests (RT) and selected type tests (ref. to applicable class programs) checked (if not available these tests shall be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer’s product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years.
 A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE