



EU Type Examination Certificate CML 19ATEX3380 Issue 3

- 1 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU
- 2 Equipment **FreezStop Extra Wide/FailSafe Extra Wide (FSEw) Self-Regulating Heating Cable**
- 3 Manufacturer **Heat Trace Limited** **Heat Trace Hitech Co., Ltd**
- 4 Address

	Mere's Edge, Chester Road, Helsby, Frodsham, Cheshire, WA6 0DJ, United Kingdom	Cromwell Road, Bredbury, Stockport, SK6 2RF, United Kingdom	Unit 9 Southside, Bredbury Industrial Estate, Bredbury, Stockport, SK6 2SP, United Kingdom	527-54, Daegotbuk-ro, Daegot-myeon Gimpo-si, Gyeonggi-do, 10028, Republic of Korea
--	-------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------


- 5 The equipment is specified in the description of this certificate and the documents to which it refers.
- 6 CML B.V., Chamber of Commerce No 6738671, Koopvaardijweg 32, 4906CV Oosterhout, The Netherlands, Notified Body Number 2776, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 12.
- 7 If an 'X' suffix appears after the certificate number, it indicates that the equipment is subject to conditions of safe use (affecting correct installation or safe use). These are specified in Section 14.
- 8 This EU Type Examination certificate relates only to the design and construction of the specified equipment or component. Further requirements of Directive 2014/34/EU Article 13 apply to the manufacture of the equipment or component and are separately certified.
- 9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:

EN IEC 60079-0:2018

EN 60079-30-1:2017

- 10 The equipment shall be marked with the following:



Ex 60079-30-1 IIC T4 Gb¹

Ex 60079-30-1 IIC T3 Gb²

Ex 60079-30-1 IIIC T135°C Db¹

Ex 60079-30-1 IIIC T200°C Db²

IP67

Withstand temp range: -40°C to +100°C

¹ For nominally rated 230 V products up to 45 W/m powered up to a maximum 277 V

² For nominally rated 230 V products above 45 W/m powered up to a maximum 277 V





CML 19ATEX3380
Issue 3

11 Description

The FreezStop Extra Wide/FailSafe Extra Wide (FSEw) Self-Regulating Heating Cable comprises two parallel buswires housed within a semi-conductive self-limiting matrix. The semi-conductive self-limiting matrix is covered with a thermoplastic insulation jacket which is then protected by an aluminium sheath or a metallic braid. An optional outer jacket of TPE, PE, PVDF, MFA or PFA can be specified. The cables are rated at up to 75 W/m and 277 V.

The cable is intended to be cut to length on site and the equipment is designed to be connected to a supply by means of suitable certified cable entries and junction boxes (i.e. Ex e or Ex d) in accordance with the manufacturer's installation instructions. Termination can be made using the Heat Trace termination kits approved under CML 19ATEX3390U and CML 19ATEX3391U or any suitably certified type termination kit which fully isolate, insulate and seal the conductive cores.

Description	Temperature
Max. continuous exposure temperature (Power ON)	100°C
Max. permissible exposure temperature (Power OFF)	100°C
Minimum installation temperature	-40°C

Variation 1

This variation introduced the following changes:

- i. To update the standard reference from EN 60079-30-1:2007 to EN 60079-30-1:2017 and to update the equipment marking accordingly.

Variation 2

This variation introduced the following changes:

- i. Drawings updated to clarify the use of T4/T135°C marking option for products rated up to 45 W/m

Variation 3

This variation introduced the following changes:

- i. Introduction of alternative braid options with new product references
- ii. Correction from previous assessment to include additional manufacturing locations
- iii. Typographical correction to the product description

12 Certificate history and evaluation reports

Issue	Date	Associated report	Notes
0	09 Dec 2019	R12696A/00	Issue of Prime Certificate
1	19 May 2020	R13195A/00	Introduction of Variation 1
2	10 May 2021	R13992A/00	Introduction of Variation 2
3	28 Jun 2022	R15271A/00	Introduction of Variation 3

Note: Drawings that describe the equipment or component are listed in the Annex.



CML 19ATEX3380
Issue 3

13 Conditions of Manufacture

The following conditions are required of the manufacturing process for compliance with the certification.

- i. An electric strength test of $2 U + 1000$ V rms shall be applied between the conductors and the outer braid or sheath as appropriate for 60 seconds in accordance with the requirements of EN 60079-30-1:2017 clause 5.1.2.
- ii. An electric strength test of the polymeric sheath (over jacket) used for corrosion resistance shall be carried out in accordance with the requirements of EN 60079-30-1:2017 clause 5.2.1.
- iii. The manufacturer shall verify the output rating for each cable manufactured in accordance with the requirements of EN 60079-30-1:2017 clause 5.2.2.
- iv. The manufacturer shall demonstrate, through their quality program, the thermal safety of the trace heating cable with respect to time in accordance with the requirements of EN 60079-30-1:2017 clause 5.1.12.

14 Specific Conditions of Use (Special Conditions)

None.

Certificate Annex

Certificate Number CML 19ATEX3380
Equipment FreezStop Extra Wide/FailSafe Extra Wide (FSEw) Self-Regulating Heating Cable
Manufacturer Heat Trace Limited



The following documents describe the equipment or component defined in this certificate:

Issue 0

Drawing No	Sheets	Rev	Approved date	Title
HC3200/C	1 of 1	10	09 Dec 2019	Certification Drawing for FreezStop Extra (W)
FSEw Markings	1 of 1	0	09 Dec 2019	FSEw Heating Cable – ATEX and IECEx Markings
FSEw Drum Label	1 of 1	0	09 Dec 2019	Cable Drum Label – For Cable Type FSEw
HTML-15/C	1 of 1	0	09 Dec 2019	Certification Drawing for FSEw Marking Label
HTML-16/C	1 of 1	0	09 Dec 2019	FSEw ATEX & IECEx Label

Issue 1

Drawing No	Sheets	Rev	Approved date	Title
FSEw Markings	1 of 1	1	19 May 2020	FSEw Heating Cable – ATEX and IECEx Markings
HTML-15/C	1 of 1	1	19 May 2020	Certification Drawing for FSEw Marking Label
HTML-16/C	1 of 1	1	19 May 2020	FSEw ATEX & IECEx Label

Issue 2

Drawing No	Sheets	Rev	Approved date	Title
FSEw MARKINGS	1 to 2	4	10 May 2021	FSEw HEATING CABLE – ATEX and IECEx MARKINGS
HTML-K-15-C Rev 0	1 of 1	0	10 May 2021	KOREA CERTIFICATION DRAWING FOR FSEw MARKING LABEL
HTML-K-16-C Rev 0	1 of 1	0	10 May 2021	KOREA FSEw ATEX & IECEx LABEL

Certificate Annex

Certificate Number CML 19ATEX3380
Equipment FreezStop Extra Wide/FailSafe Extra Wide (FSEw) Self-Regulating Heating Cable
Manufacturer Heat Trace Limited



Issue 3

Drawing No.	Sheets	Rev	Approved date	Title
HC3200/C	1 of 1	12	28 Jun 2022	Certification for Freezstop Extra Type FSEw
FSE Markings	1 to 2	5	28 Jun 2022	FSEw Heating Cable- ATEX and IECEx Markings