



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEX CML 19.0123	Page 1 of 5	<u>Certificate history:</u>
Status:	Current	Issue No: 3	Issue 2 (2021-05-10)
Date of Issue:	2022-06-28		Issue 1 (2020-05-19)
Applicant:	Heat Trace Limited Mere's Edge Chester Road Helsby Cheshire Helsby WA6 0DJ United Kingdom		Issue 0 (2019-12-09)
Equipment:	FreezStop Extra Wide/FailSafe Extra Wide (FSEw) Self-Regulating Heating Cable		
Optional accessory:			
Type of Protection:	Trace Heating "60079-30-1"		
Marking:	Ex 60079-30-1 IIC T4 Gb ¹ Ex 60079-30-1 IIIC T135°C Db ¹ Ex 60079-30-1 IIC T3 Gb ² Ex 60079-30-1 IIIC T200°C Db ² IP67 Withstand temp range: -40°C to +100°C ¹ For nominally rated 230 V products up to 45 W/m powered up to a maximum 277 V ² For nominally rated 230 V products above 45 W/m powered up to a maximum 277 V		

Approved for issue on behalf of the IECEx
Certification Body:

L A Brisk

Position:

Certification Officer

Signature:
(for printed version)

Date:
(for printed version)

2022-06-28

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

Eurofins E&E CML Limited
Unit 1, Newport Business Park
New Port Road
Ellesmere Port, CH65 4LZ
United Kingdom





IECEX Certificate of Conformity

Certificate No.: **IECEX CML 19.0123**

Page 2 of 5

Date of issue: 2022-06-28

Issue No: 3

Manufacturer: **Heat Trace Limited**
Mere's Edge
Chester Road
Helsby
Cheshire
Helsby WA6 0DJ
United Kingdom

Manufacturing
locations: **Heat Trace Limited**
Mere's Edge
Chester Road
Helsby
Cheshire
Helsby WA6 0DJ
United Kingdom

Heat Trace Limited
Cromwell Road
Bredbury
Stockport, SK6 2RF
United Kingdom

Heat Trace Limited
Unit 9 Southside
Bredbury Industrial Estate
Bredbury
Stockport SK6 2SP
United Kingdom

See following pages for more locations

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

[IEC 60079-0:2017](#) Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

[IEC/IEEE 60079-30-1:2015](#) Explosive atmospheres - Part 30-1: Electrical resistance trace heating - General and testing requirements
Edition:1.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

[GB/CML/ExTR19.0146/00](#)
[GB/CML/ExTR22.0087/00](#)

[GB/CML/ExTR20.0122/00](#)

[GB/CML/ExTR21.0067/00](#)

Quality Assessment Reports:

[GB/CML/QAR19.0027/04](#)

[GB/CML/QAR20.0028/01](#)



IECEX Certificate of Conformity

Certificate No.: **IECEX CML 19.0123**

Page 3 of 5

Date of issue: 2022-06-28

Issue No: 3

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The FreezStop Extra Wide/FailSafe Extra Wide (FSEw) Self-Regulating Heating Cable comprises two parallel buswires housed within a semi-conductive self-limiting matrix. The semi-conductive self-limiting matrix is covered with a thermoplastic insulation jacket which is then protected by an aluminium sheath or a metallic braid. An optional outer jacket of TPE, PE, PVDF, MFA or PFA can be specified. The cables are rated at up to 75 W/m and 277 V.

Refer to Annex for full description and conditions of manufacture.

SPECIFIC CONDITIONS OF USE: NO



IECEX Certificate of Conformity

Certificate No.: **IECEX CML 19.0123**

Page 4 of 5

Date of issue: 2022-06-28

Issue No: 3

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

Issue 1

This issue introduced the following changes:

1. To update the standard references from IEC 60079-30-1:2007 Ed. 1 to IEC/IEEE 60079-30-1:2015 Ed. 1 and to update the equipment marking accordingly.

Issue 2

This issue introduced the following changes:

1. To recognise an additional manufacturing location.
2. Drawings updated to clarify the use of T4/T135°C marking option for products rated up to 45 W/m.

Issue 3

This issue introduced the following changes:

1. Introduction of alternative braid options with new product references
2. Correction from previous assessment to include additional manufacturing locations
3. Typographical correction to the product description



IECEX Certificate of Conformity

Certificate No.: **IECEX CML 19.0123**

Page 5 of 5

Date of issue: 2022-06-28

Issue No: 3

Additional manufacturing locations:

Heat Trace Hitech Co., Ltd
527-54, Daegotbuk-ro, Daegot-myeon
Gimpo-si
Gyeonggi-do 10028
Korea, Republic of

Annex:

[Certificate Annex IECEx CML 19.0123 Issue 3.pdf](#)

Annexe to: IECEx CML 19.0123 Issue 3
Applicant: Heat Trace Limited
Apparatus: FreezStop Extra Wide/FailSafe Extra Wide (FSEw) Self-Regulating Heating Cable

Description

The FreezStop Extra Wide/FailSafe Extra Wide (FSEw) Self-Regulating Heating Cable comprises two parallel buswires housed within a semi-conductive self-limiting matrix. The semi-conductive self-limiting matrix is covered with a thermoplastic insulation jacket which is then protected by an aluminium sheath or a metallic braid. An optional outer jacket of TPE, PE, PVDF, MFA or PFA can be specified. The cables are rated at up to 75 W/m and 277 V.

The cable is intended to be cut to length on site and the equipment is designed to be connected to a supply by means of suitable certified cable entries and junction boxes (i.e. Ex e or Ex d) in accordance with the manufacturer’s installation instructions. Termination can be made using the Heat Trace termination kits approved under CML 19ATEX3390U and CML 19ATEX3391U or any suitably certified type termination kit which fully isolate, insulate and seal the conductive cores.

Description	Temperature
Max. continuous exposure temperature (Power ON)	100°C
Max. permissible exposure temperature (Power OFF)	100°C
Minimum installation temperature	-40°C

Conditions of Manufacture

The following conditions are required of the manufacturing process for compliance with the certification.

- i. An electric strength test of $2 U + 1000 V$ rms shall be applied between the conductors and the outer braid or sheath as appropriate for 60 seconds in accordance with the requirements of IEC/IEEE 60079-30-1: 2015 Ed.1 clause 5.1.2.
- ii. An electric strength test of the polymeric sheath (over jacket) used for corrosion resistance shall be carried out in accordance with the requirements of IEC/IEEE 60079-30-1: 2015 Ed.1 clause 5.2.1.

Eurofins E&E CML Limited
 Newport Business Park
 New Port Road
 Ellesmere Port
 CH65 4LZ

T +44 (0) 151 559 1160
 E info@cmlex.com

www.cmlex.com

Company Reg No. 8554022 VAT No. GB163023642





- iii. The manufacturer shall verify the output rating for each cable manufactured in accordance with the requirements of IEC/IEEE 60079-30-1: 2015 Ed.1 clause 5.2.2.
- iv. The manufacturer shall demonstrate, through their quality program, the thermal safety of the trace heating cable with respect to time in accordance with the requirements of IEC/IEEE 60079-30-1: 2015 Ed.1 clause 5.1.12.

Specific Conditions of Use

None.